



**Planning, Development  
and Transportation**  
Transportation Planning  
305 Chestnut Street  
PO Box 1810  
Wilmington, NC 28402-1810

**DATE:** 09.28.2015

**TO:** ProTrak

**FROM:** Bill McDow  
Transportation Planning

910 341-3258  
910 341-7801 fax  
[www.wilmingtonnc.gov](http://www.wilmingtonnc.gov)  
Dial 711 TTY/Voice

---

■ **BOJANGLES COLLEGE RD [TRC Plan Review# 3]**



**TECHNICAL STANDARDS – DRIVEWAY ACCESS (Major Thoroughfares):**

1. Please verify the position of the solid white pavement marking line associated with the new turn lane. The NCDOT Driveway plan appears to be adding a solid white edge line along the entire length of the turn lane.
2. Please modify the pavement markings for the turn lane per MUTCD, NCDOT and City of Wilmington standards. Ensure the turn lane has marked arrows and wording that indicate that the Right Lane is not a through lane.

**TECHNICAL STANDARDS – PARKING:**

3. The proposed CO2 tank in the waste enclosure appears to be exposed. Please add more bollards to provide protection for the tank as the waste receptacles are loaded and unloaded in this area.
4. The 60 degree parking space at the NW corner of the parking lot (closest to the 24" Oak Tree) appears to be protruding into the travel aisle. One side of the space has the 20' required length, however, the curb side of the parking space appears to have ~18 length.

Please let me know if you have any questions or if I can be of further assistance as this development moves through the review process.